



ISO 9001:2008 CERTIFIED

ENGINEERS • PLANNERS • SCIENTISTS • CONSTRUCTION MANAGERS

801 Travis Street, Suite 2000 • Houston, TX 77002 • Office 713-237-9800 • Fax 713-237-9801

CITY COMMENT FORM

CITY OF SUGARLAND PLAN CHECKING DEPARTMENT COMMENT RESPONSES

ATTENTION: Dwayne A. Svatek

FROM: Paul Corley

CITY PROJECT NO: 18-7314

DATE: 2/13/2019

MECHANICAL **ELECTRICAL** **PLUMBING** **FIRE**

City/County Comment:

ITEM 1: Provide grease interceptor sizing calculation.

ITEM 1 RESPONSE:

The grease interceptor is a mechanical grease trap and is sized base on a 4" Diameter Maximum Flow Rate of 125 GPM.

See detail on P3.02 for model number and flow rate demand.

Please contact Paul Corley immediately at 832-975-1510 if this does not meet your requirements.

Thank you.